

Our Ref: CR/JC
30 May 2007

VIP Polymers Ltd
15 Windover Road
Huntingdon
Cambridgeshire
PE29 7EB

WRAS
Water Regulations Advisory Scheme

WATER REGULATIONS ADVISORY SCHEME

"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS.6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

RUBBER - EPDM COMPONENTS

5360

Cold water use only:

EW 45 - 45 IRHD

EW 50 - 50 IRHD Black coloured EPDM sealing rings.

Cold water and hot water use up to 60°C:

EW 53 - 55 IRHD

EW 60 - 60 IRHD

EW 65 - 65 IRHD

EW 70 - 70 IRHD

EW 75 - 75 IRHD

EW 80 - 80 IRHD

EW 81 - 80 IRHD

EW 85 - 85 IRHD Black coloured EPDM sealing rings.

For use only as an elastomeric seal for pipe joints and fittings that will be used with water main pipes of 15mm or greater.

Test Report: M103562B/M103639, M103468/B, M103969C/M103997C, M103969/B&A

0702518

VIP POLYMERS LTD

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in February 2012.

Yours faithfully

Chris Ramsey (Miss)

Materials Approval - Water Regulations Advisory Scheme

Water Regulations Advisory Scheme

30 Fern Close, Pen-y-Fan Industrial Estate,
Oakdale, Gwent NP11 3EH, UK.

Tel: 01495 248454. Fax: 01495 249234.

E-mail: info@wras.co.uk Website: www.wras.co.uk

WRAS Ltd
Registered in England No. 3771280
Registered Office: Pen-y-Fan Road,
Huntingdon, Cambridgeshire,
Huntingdon PE29 7EB, England



materiales de fundición s.a.

TUBERIA DE FUNDICION DUCTIL